


Ref No. 204/23

Date : 19/04/23

**SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE**

This is to certify that *M/s SACRED HEART ENGLISH MEDIUM SCHOOL, MOOKKANNUR* (Affiliated to CBSE No.930681, School Code.75654) situated at Ward-05, Mookkannur Grama Panchayat has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per the norms prescribed by the Central/State/U.T Govt. There is proper waste disposal system. Air ventilation and toilet facilities are satisfactory.

This certificate is valid for a period from 19/04/23 to 31/03/2024.

  
19/04/2023

HEALTH INSPECTOR

PHC, MOOKKANNUR

HEALTH INSPECTOR  
PHC MOOKKANNUR  
ERNAKULAM



# GLOBAL LABS & CONSULTANTS

(A DIVISION OF PERIYAR BIOTECH (PVT) LTD.)

AN ISO 9001 : 2015 & 14001 : 2015 CERTIFIED COMPANY

Approved by Kerala State Pollution Control Board  
Empanelled By Suchitwa Mission

## REPORT ON ANALYSIS OF DRINKING WATER

1. Source of Sample: Open well		2. Ref. No: GLC/D/30323009			
3. Sample Collected by: Client		4. Date of collection: 23.03.2023			
5. Period of Analysis: 23.03.2023 - 25.03.2023		6. Prepared on: 25.03.2023			
7. Client Address: Sacred Heart English Medium School, Mookkannoor, Ph:9847033535.					
Sl. No	Characteristics	Unit	Methods	Desirable Limits	Actual Contents
1	pH		IS:3025(Pt.11)1983	6.5-8.5	5.57
2	Conductivity	µs/cm	IS:3025(Pt.14)1984	800	160
3	Total Dissolved Solids	mg/l	IS:3025(Pt.15)1984	500	96
4	Turbidity	NTU	IS:3025(Pt.10)1984	05	<1
5	Methyl orange alkalinity as CaCO <sub>3</sub>	mg/l	IS:3025(Pt.23)1986	200	24
6	Total Hardness as CaCO <sub>3</sub>	mg/l	IS:3025(Pt.21)1983	300	68
7	Calcium	mg/l	IS:3025(Pt.40)1991	75	03
8	Magnesium	mg/l	IS:3025(Pt.46)1994	30	16
9	Chloride	mg/l	IS:3025(Pt.32)1988	250	28
10	Sulphate as SO <sub>4</sub>	mg/l	IS:3025(Pt.24)1986	150	<1
11	Iron as Fe	mg/l	IS:3025(Pt.53)2003	0.3	<0.01
12	Sodium	mg/l	IS:3025(Pt.45)1993	70	18
13	Total Plate Count	cfu/ml	IS:5402:1969	100	80
14	Total Coliform	MPN/100ml	IS:5401:1969	Nil	Nil

Remarks: pH is less than the standard limit of drinking water.

CHEMIST

### Registered Office

Global House, Mekkad P.O., Karakkattukunnu  
Nedumbassery, Emakuiam Dt. Kerala - 683589  
Phone : 04847180654, 9446429151  
website : www.globallabscochin.com  
Email : periyarbiotech@gmail.com

R & D Laboratory  
Mob : 9562800846  
Email : globallabskuzhur@gmail.com

Warehouse  
Mob : 9562800848  
Bamboo House, Kuzhur P.O.

**Crows<sup>®</sup>**

Home Care, Personal Hygiene  
and Cosmetic Products  
Bamboo House Kuzhur.P.O  
www.crowsplus.com.  
customercare@crowspplus.com,  
Customer care : 9562800841